



European Union Agency for the Cooperation
of Energy Regulators


Core Long Term Capacity Calculation Methodology

Zoran Vujasinović, Martin Viehhauser ACER-ELE-2021-012

Public Consultation WORKSHOP
9 July 2021, 10:00 - 11:15

- please keep mic muted and camera off
- you may pose questions via chat
- all attendees will view all questions and replies in chat
- if further clarifications are needed, you will be asked to open your mic and comment
- Q&A session is after each agenda item
- the slides will be shared with you

	Topic	Time
1	Opening	10.00 - 10.05
2	General provisions of Core LT CCM Q&A, discussion	10.05 - 10.15
3	Capacity calculation inputs Q&A, discussion	10.15 - 10.30
4	Capacity calculation and validation Q&A, discussion	10.30 - 10.50
5	Fallback, data, implementation Q&A, discussion	10.45 - 11:00
6	Q&A on other topics, discussion, closing	11.00 - 11.15



General provisions of Core LT CCM

- Core LT CCM shall be applied for the yearly and monthly timeframe
- It shall apply the flow-based (FB) approach
- It shall apply the multiple scenarios (Common Grid Models) for calculation of FB parameters
- It shall provide the FB parameters (PTDF/RAM) for explicit flow-based auctions with Options



Topic: Application of the flow-based approach

- ACER supports the application of a FB approach, as in line with the FCA and CACM Regulation
- FB approach: appropriate for meshed networks such as the Core CCR and consistent with the approach applied in Core Day-ahead CCM (Core DA FB goes-live Feb 2022)
- The efforts to implement the Coordinated NTC approach in Core CCR have failed:
 - no agreement how to split the interdependent cross-zonal capacities among Core borders
 - For FB such split is not necessary: FB allocation determines the volume of allocated capacities per each border based on maximisation of economic surplus

Topic: Application of the flow-based approach

- In order to apply the FB approach on LT level, ACER requested by all TSOs to amend the documents related to FCA Regulation:
 - requirements for the single allocation platform (SAP)
 - harmonised allocation rules (HAR)
 - congestion income distribution methodology (CiD)
 - methodology for sharing costs for firmness and remuneration of LT transmission rights (FRC)

Q&A (5-10')



Provide your questions on the subject in the chatbox

We will group the questions and try to provide an answer and may ask to further explain if necessary.

Capacity calculation inputs

- Critical Network Elements and associated Contingencies (CNEC) [dedicated slide provided →](#)
- Allocation (external) constraints [dedicated slide provided →](#)
- Common Grid Models (Scenarios) [dedicated slide provided →](#)
- Operational Security Limits (Fmax)
- Reliability Margin (FRM)
 - The FRM values from DA level shall be applied, under the assumptions related to the Common Grid Models
- Generation Shift Keys (GSK)
- Remedial Actions (RA)
 - The coordinated optimisation of RA shall not be applied for LT CC, due to the uncertainty of RA forecasting at a long timeframe
- HVDCs at Core borders
 - The Evolved Flow Based (EFB) principles shall be applied for cross-border HVDCs, as in the Core DA

Topic: Selection of critical network elements

- The initial TSOs Proposal allowed the TSOs to include additional internal CNECs in the LT CC, on top of those defined in the initial day-ahead CNEC list
- As argued by the Core TSOs:
 - required to avoid negative financial consequences for the TSOs in case of over-allocation at LT level, and the need to accommodate such LTA at the day-ahead level
- **ACER is of the view that the LT CNEC list should be consistent with the DA CNEC list**
 - According to the Core DA CCM, day-ahead validation cannot lower the remaining available margin (RAM) values below the level required to accommodate the long-term allocation. As such, ACER sees no financial risk to the TSOs
 - ACER also considers it unlikely that LT over-allocate and thus endanger the security, since it applies conservative approach in simultaneous application of constraints by all scenarios, and no-netting of counter flows

Topic: Application of allocation (external) constraints

- The LT CCM provides a possibility for TSOs to apply the allocation constraints (external constraints, i.e. export/import limits) on top of the flow-based parameters
- ACER notes that external constraints are currently exercised by TenneT (the Netherlands) and PSE (Poland) in the DA timeframe
 - ACER understands that as long as the external constraints are applied at the day-ahead level, they are also required at the long-term level, in order to accommodate the day-ahead external constraints and avoid over-allocation at the long-term level
 - ACER reminds that external constraints (at DA) can be applied only if there is no other alternative to efficiently model the system limitations (through FB parameters)
 - ACER also proposes to strengthen the monitoring of the applied values of external constraints



Topic: Common Grid Models (Scenarios)

- ACER’s position: standard LT scenarios (CGMs) should be used pursuant to CGM Methodology (CGMM), for the Core LT CCM go-live
 - Yearly CGMs (8 per year)
 - Monthly CGMs (2 per month)
- **ACER aims for the coordinated use of LT CGMs across Europe, as provided in CGMM**
- The situations where the temporary of general improvements might be needed:

Issue	Comment	Proposal
Some CGMs are not yet implemented	E.g. monthly CGMs are missing	TSOs can establish the temporary regional procedure To be applied until the CGMM-compliant solution is implemented
TSOs require better granularity of CGMs for LT CC	Y: 8 CGMs/y → 24 CGMs/y M: 2 CGMs/m → 2 CGMs/week	The temporary regional procedure is possible here as well, <u>ONLY IF</u> : 1. This does not endanger the go-live date 2. The temporary solution is low-effort and low-data 3. The TSOs and ENTSOE would ASAP forward this procedure as CGMM amendment, to become EU-wide
TSOs require actual planned topology per timestamp implemented at CGMs	Actual CGMM models apply outage only if element is out for the whole period	

Q&A (5-10')



Provide your questions on the subject in the chatbox

We will group the questions and try to provide an answer and may ask to further explain if necessary.

Capacity calculation and validation

- Calculation:

	Calculation	Comment
PTDF calculation	$PTDF_{\text{zone-to-slack}} = PTDF_{\text{node-to-slack}} * GSK_{\text{node-to-zone}}$ $PTDF_{\text{zone1} \rightarrow \text{zone2}} = PTDF_{\text{zone1-to-slack}} - PTDF_{\text{zone2-to-slack}}$	Linearized calculation of PTDFs (DC); PTDF sensitivity threshold is <u>not</u> foreseen (to omit the small PTDFs during allocation)
Reference flows	$\vec{F}_{0,\text{Core}} = \vec{F}_{\text{ref}} - PTDF_f \overrightarrow{\text{Exchanges}}_{\text{ref,Core}}$	\vec{F}_{ref} shall be calculated with AC Load Flow by default
Remaining Available Margin (initial)	$RAM_{\text{ (initial)}} = F_{\text{max}} - FRM - \vec{F}_{0,\text{Core}} - F_{\text{AAC}}$	Initial RAM before minRAM implementation
minRAM inclusion	$RAM_{\text{ (initial)}} + F_{\text{AAC}} \geq R_{\text{amr}} * F_{\text{max}_1} = \text{AMR}$ $\text{AMR} = \max(0; R_{\text{amr}} * F_{\text{max}} - (F_{\text{max}} - FRM - F_{0,\text{Core}}) - F_{\text{AAC}})$	AMR - Adjustment of Minimum RAM dedicated slide provided →
Remaining Available Margin (before validation)	$RAM_{\text{bv}} = F_{\text{max}} - FRM - F_{0,\text{Core}} - F_{\text{AAC}} + \text{AMR}$	

- Validation: Individual validation - data issues, voltage, reactive power flows, influence of RA

Topic: Minimum remaining available margin (RAM)

$R_{amr} = 20\%(F_{max})$ was the initially proposed level of minRAM

- minRAM: important threshold, ensuring the minimum level of allocation available at LT timeframe
- 20% reflects the current minRAM applied at the day-ahead CWE flow-based approach
- ACER is concerned that this level may likely lead to much lower LT cross-zonal capacities

minRAM	Auctions – flows	Likelihood of minRAM utilisation	Consequence
DA level	With Obligations ⇒ allows for netting of counter flows	High	Low minRAM
LT level	With Options ⇒ does not allow for netting of counter flows	Low	Higher minRAM than the one on DA

- ACER investigates the effect of no netting on minimum RAM, and level of offered capacities, and propose a higher minimum RAM value for the LT if possible
- In addition, ACER investigates the options of:
 - a) using historical long-term NTCs converted into minimum RAM, or
 - b) statistical analysis of day-ahead RAMs ⇒ providing minimum applied DA RAM, to be used for LT minRAM

Topic: Capacity Calculation outputs

- Final FB parameters: PTDF/RAM after validation
 - Defining “union” of CNECs from all scenarios as a set of constraints to the LT auction

Illustration: Union of RAM&PTDF parameters from all scenarios for Y timeframe

Scenario (Y)	CNEC	RAM	PTDFs		
1 Jan-peak	CNEC 1	950	0.06	0.5	0.2 ...
	CNEC 2	900	0.07	0.44	0.22 ...
	CNEC 3	500	0.33	0.06	0.3 ...

	CNEC N	1100	0.08	0.06	0.3 ...
2 Jan-offpeak	CNEC 1	1100	0.055	0.44	0.22 ...
	CNEC 2	910	0.07	0.44	0.22 ...
	CNEC 3	520	0.33	0.06	0.3 ...

	CNEC N	1110	0.07	0.06	0.3 ...
...
8 Dec-offpeak	CNEC 1	1000	0.06	0.48	0.21 ...
	CNEC 2	880	0.07	0.45	0.22 ...
	CNEC 3	550	0.23	0.06	0.3 ...

	CNEC N	1110	0.08	0.055	0.29 ...

union of constraints from all scenarios at Y timeframe

- The same CNECs are repeated multiple times, but are calculated on the basis of different CGMs
- Presolve function will remove redundant constraints
 - (e.g: CNEC1 from Jan-peak “covers” the CNEC1 in Jan-offpeak)

Q&A (5-10')



Provide your questions on the subject in the chatbox

We will group the questions and try to provide an answer and may ask to further explain if necessary.

Review, updates, data and implementation

- Fallback
 - Usage of previous FB parameters (from corresponding timestamp) is foreseen as a fallback in case of implausible FB calculation
- Data publication
 - In general aligned with the Core DA CCM process
- Review, updates, implementation dedicated slide provided →

Topic: Implementation timeline and revision

- The TSOs Proposal foresaw the implementation timeline for the LT CCM of up to **5 years**
- The Core NRAs and ACER are of the view that this timescale is excessively long compared to the developments required
- The Core NRAs recommended shorter implementation timeline for the LT CCM and, where possible, application of the already existing experiences/tools
- CWE FB already provides significant experience, and will be extended to the entire Core - Feb22
- **ACER proposal:**
 - The go-live methodology is being designed as simple as possible
 - For this reason, ACER proposed the **go-live within 2.5 years** after issuing the Decision: i.e. monthly auction July 2024 and yearly auction 2025
 - to allow for a subsequent **revision of the methodology 18 months after the go-live**
- Core TSOs have raised numerous concerns about the non-simultaneous switch to flow-based yearly and monthly auctions, so this issue has still been discussed

Q&A (...11:15)



Provide your questions on the subject in the chatbox

We will group the questions and try to provide an answer and may ask to further explain if necessary.

Thank you for your attention.



European Union Agency for the Cooperation
of Energy Regulators

✉ info@acer.europa.eu
🖱 acer.europa.eu

🐦 [@eu_acer](https://twitter.com/eu_acer)
🌐 [linkedin.com/in/EU-ACER/](https://www.linkedin.com/in/EU-ACER/)